



**BUREAU
VERITAS**

Świadectwo zgodności

Zgłaszający:

JIANGSU GOODWE POWER SUPPLY TECHNOLOGY CO., LTD
No.90 ZiJin Rd., New District,
Suzhou, 215011
China

Produkt:

Sieciowy falownik fotowoltaiczny (PV)

Model:

**GW700-XS
GW1000-XS
GW1500-XS
GW2000-XS
GW2500-XS
GW3000-XS**

Zastosowanie zgodnie z przepisami:

Automatyczne urządzenie wyłączające, monitorujące sieć jednofazową w systemach fotowoltaicznych z obwodem równoległym jednofazowym poprzez przetwornicę w publicznej sieci zasilania. Automatyczne urządzenie wyłączające stanowi część wyżej wymienionej przetwornicy.

Zastosowane przepisy i normy:

EN 50549-1:2019, PN-EN 50549-1:2019

Wymagania dla instalacji generacyjnych przeznaczonych do równoległego przyłączenia do publicznych sieci dystrybucyjnych -- Część 1: Przyłączenie do sieci dystrybucyjnej nN -- Instalacje generacyjne aż do typu B i włącznie z nim

EN 50438:2013, PN-EN 50438:2014

Wymagania dla instalacji mikrogeneracyjnych przeznaczonych do równoległego przyłączenia do publicznych sieci dystrybucyjnych niskiego napięcia

DIN V VDE V 0126-1-1:2006 (4.1 Bezpieczeństwo Funkcjonalne)

Automatyczne urządzenie odłączające między generatorem a publiczną siecią niskiego napięcia

W momencie wydania niniejszego certyfikatu pojęcie zabezpieczenia interfejsu wyżej wymienionego, reprezentatywnego produktu spełnia wymagania bezpieczeństwa obowiązujące dla określonego zastosowania zgodnie z przepisami.

Numer raportu: ZEM-19JY3071FTSHP

Program certyfikacji: NSOP-0032-DEU-ZE-V01

Numer świadectwa: U20-0205

Data wydania: 2020-03-31

Instytut certyfikacji



Holger Schaffer



Instytut certyfikacji Bureau Veritas Consumer Products Services Germany GmbH akredytowane zgodnie z normą DIN EN ISO/IEC 17065

Uma representação parcial do certificado requer a aprovação por escrito do Bureau Veritas Consumer Products Services

Appendix

Extract from test report according to EN 50549-1

Nr. ZEM-19JY3071FTSHP

Type Approval and declaration of compliance with the requirements of EN 50549-1.

Manufacturer / applicant:	JIANGSU GOODWE POWER SUPPLY TECHNOLOGY CO., LTD No.90 ZiJin Rd., New District, Suzhou, 215011 China
----------------------------------	--------------------------------------------------------------------------------------------------------------

Micro-generator Type	Grid-tied photovoltaic inverter			
	GW700-XS	GW1000-XS	GW1500-XS	GW2000-XS
MPP DC voltage range [V]	50 - 450			
Input DC voltage range [V]	max. 500	max. 500	max. 500	max. 500
Input DC current [A]	12,5	12,5	12,5	12,5
Output AC voltage [V]	220/230	220/230	220/230	220/230
Output AC current [A]	3,5	4,8	7,2	9,6
Output power [W]	700	1000	1500	2000
Output power [VA]	800	1100	1650	2200

	GW2500-XS	GW3000-XS		
MPP DC voltage range [V]	50 - 450			
Input DC voltage range [V]	max. 500	max. 500		
Input DC current [A]	12,5	12,5		
Output AC voltage [V]	220/230	220/230		
Output AC current [A]	12,0	14,3		
Output power [W]	2500	3000		
Output power [VA]	2750	3300		

Firmware version	V1.00.08
-------------------------	----------

Measurement period:	2019-12-23 to 2020-03-02
----------------------------	--------------------------

Description of the structure of the power generation unit:

The power generation unit is equipped with a PV and line-side EMC filter. The power generation unit has no galvanic isolation between DC input and AC output. Output switch-off is performed with single-fault tolerance based on two series-connected relays in each line and neutral. This enables a safe disconnection of the power generation unit from the network in case of error.

Appendix

Extract from test report according to EN 50549-1

Nr. ZEM-19JY3071FTSHP

Setting of the interface protection:

Parameter	Max. disconnection time	Min. operate time	Trip value
Over voltage (stage 1) ^a	3s	-	230V +10% (253V)
Over voltage (stage 2)	0,2s	0,1s	230V +15% (264,5V)
Under voltage	1,5s	1,2s	230V -15% (195,5V)
Over frequency	0,5s	0,3s	50Hz +4% (52 Hz)
Under frequency	0,5s	0,3s	50Hz -5% (47,5 Hz)
Reconnection settings for voltage (normal operational startup)	$0,85V_n (195,5V) \leq V \leq 1,10V_n (253V)$		
Reconnection settings for frequency (normal operational startup)	$49,5Hz \leq f \leq 50,1Hz$		
Reconnection time (normal operational startup)	$\geq 60s$		
Reconnection settings for voltage (automatic reconnection after tripping)	$0,85V_n (195,5V) \leq V \leq 1,10V_n (253V)$		
Reconnection settings for frequency (automatic reconnection after tripping)	$49,5Hz \leq f \leq 50,1Hz$		
Reconnection time (automatic reconnection after tripping)	$\geq 60s$		
Active power gradient after reconnection	10% $P_{E_{max}}$ / per minute		
Active power delivery at under frequency	electronic inverter, no active power reduction		
Power response to over frequency (frequency / droop s)	50,2Hz / 5%		
Permanent DC-injection	0,5% of rated inverter output current or 20mA		
Rate of change of frequency (ROCOF)	2Hz/s		
Loss of mains according EN 62116 (LoM)	2,0s		

Note:

^a Over voltage – stage1: 10 min-mean-value corresponding to EN 50160.

Default interface setting according to EN 50438:2013, PN-EN 50438:2013 are used.

The settings of the interface protection are password protected adjustable.

In case the above stated generators are used with an external protection device, the protection settings of the inverters are to be adjusted according to the manufacturer's declaration.

The above stated generators are tested according to the requirements in the EN 50549-1:2019. Any modification that affects the tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements of the EN 50549-1:2019.